

---

## Plan Review Summary

---

### Building Information

Project Name:	Dalney Building-As-Builts and CSR	Floor/Room #:	All
Building #:	204	Department:	GTRC(office, PTS (Garage)
Occupancy Type:	Business	Budget:	\$39M
Construction Type:	IB	Type of Review:	As Builts and CSR

### Project Management

Project Manager:	Brad Morris
Architect/Engineer of Record:	Scott Southerland, Collins Cooper Carusi
Construction Manager:	Ryan Clear, New South Construction
Aim Project Number:	0370-2017

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/22/2019
Disposition:	Declined	Date Completed:	7/22/2019

### Status Statement

Note: Fire Alarm As-builts; Central Station Testing Report

### Review Comments:

1. The Central Station Testing report submitted is not an actual testing report. All the information is correct and is what the Central station should have for each device, however a complete testing report needs to be submitted like before that indicates the time and date tested as well as restoral times.

Please call our office and set up a meeting before moving forward with this fire alarm permit.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Alarm

### Inspections Required:

1. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Alarm