
Plan Review Summary

Building Information

| | | | |
|--------------------|-----------------------------------|-----------------|------------------------|
| Project Name: | Vamvoudakis Lab-Montgomery Knight | Floor/Room #: | Rooms 101 and 103 |
| Building #: | 101 | Department: | College of Engineering |
| Occupancy Type: | Business | Budget: | \$492,000 |
| Construction Type: | IIB | Type of Review: | Fire Alarm |

Project Management

| | |
|-------------------------------|------------------|
| Project Manager: | |
| Architect/Engineer of Record: | Bill Oswell |
| Construction Manager: | Mitchell Shelton |
| Aim Project Number: | 0004-2019 |

Reviewer Information

| | | | |
|----------------|--------------|-----------------|-----------|
| Reviewer Name: | Jake LeJeune | Date Received: | 7/23/2019 |
| Disposition: | Declined | Date Completed: | 7/23/2019 |

Status Statement

Note: 4 NEW FIRE ALARM HORN/STROBES

Review Comments:

1. Please provide battery calculations for the 4 new horn/strobes per NFPA 72.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm
-