

Plan Review Summary

Building Information

| | | | |
|--------------------|-----------------------------------|-----------------|------------------------------|
| Project Name: | Dalney Building-As-Builts and CSR | Floor/Room #: | All |
| Building #: | 204 | Department: | GTRC and PTS |
| Occupancy Type: | Business | Budget: | \$39M |
| Construction Type: | IB | Type of Review: | Fire Alarm-AS-Builts and CSR |

Project Management

| | |
|-------------------------------|--|
| Project Manager: | Brad Morris |
| Architect/Engineer of Record: | Scott Southerland, Collins Cooper Carusi |
| Construction Manager: | Ryan Clear, New South Construction |
| Aim Project Number: | 0370-2017 |

Reviewer Information

| | | | |
|----------------|--------------|-----------------|-----------|
| Reviewer Name: | Jake LeJeune | Date Received: | 7/29/2019 |
| Disposition: | Declined | Date Completed: | 7/30/2019 |

Status Statement

Note: Fire Alarm As-builts; 4th Review

Review Comments:

1. Devices on riser diagram and not on testing report:

1ST FLOOR: L1M098, L1M099, L1D003, L1M001, L1M002, L1D005, L1D006, L1D007, L1D014, L1M009, L1M006, L1M007, L1M019, L1D018, L1M031, L1D017, L1D016, L1D031, L1M013, L1M014, L1M015, L1M041

2ND FLOOR: L1D050, L1M018, L1M020, L1M019, L1D057, L1M026, L1M027, L1M028, L1M029, L1M43, L1M44, L1M45, L1M46, L1M47, L1M48

3RD FLOOR: L2M006, L2M005, L1M003, L1M004, L2M002

4TH FLOOR: L2M002, L2D078, L2D079, L1M010, L1M011, L2D071, L2D072, L2M013, L2M014, L2M015, L2M016, L2M017, L2M018, L2M019, L2D074, L2M020

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm