
Plan Review Summary

Building Information

Project Name:	Dalney Building-As-Builts and CSR	Floor/Room #:	All
Building #:	204	Department:	GTRC(office), PTS (garage)
Occupancy Type:	Business	Budget:	\$39M
Construction Type:	IB	Type of Review:	As-Builts and CSR(Fire Alarm)

Project Management

Project Manager:	Brad Morris
Architect/Engineer of Record:	Scott Southerland, Collins Cooper Carusi
Construction Manager:	Ryan Clear, New South Construction
Aim Project Number:	0370-2017

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/31/2019
Disposition:	Declined	Date Completed:	8/1/2019

Status Statement

Note: Fire Alarm As-builts; 5th Review

Review Comments:

1. First floor: L1D031 not tested
2. Fourth floor: L2D071 and L2D072 not tested; L2D078 and L2D079 need to be taken off As-builts riser diagram if they are not installed.
3. L1M10 and L1M11 both appear on the 1st floor and 4th floor riser diagram. Please clarify or revise and correct.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)