
Plan Review Summary

Building Information

Project Name:	Campus Center-Phase 1 Trailer	Floor/Room #:	Trailer Permit-Cleveland Electric
Building #:	215, 216, 217	Department:	Facilities-Design and Construction
Occupancy Type:	Business	Budget:	\$28,400,000
Construction Type:	IIB	Type of Review:	Temporary Structure-Construction

Project Management

Project Manager:	John DuConge, GT-Design and Construction
Architect/Engineer of Record:	Cooper Carry Inc.
Construction Manager:	Gilbane Building Company
Aim Project Number:	BOR-PPV-30-1801

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	8/1/2019
Disposition:	Declined	Date Completed:	8/1/2019

Status Statement

Note: Temporary Construction Trailer

Review Comments:

1. Please provide portable fire extinguishers in accordance with IFC and NFPA 10
2. Please provide a stair detail for exiting from the trailer

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm