

---

## Plan Review Summary

---

### Building Information

Project Name:	Tech Way-Fire Alarm Upgrade MRR FY19	Floor/Room #:	All Floors
Building #:	136	Department:	GT FIRE & LIFE SAFETY OFFICE
Occupancy Type:	Business	Budget:	\$500,000
Construction Type:	IIB	Type of Review:	Fire Alarm

---

### Project Management

Project Manager:	Cristina Fannin
Architect/Engineer of Record:	EMC Security/Gene Musco
Construction Manager:	Cristina Fannin
Aim Project Number:	0365-2019

---

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	8/5/2019
Disposition:	Declined	Date Completed:	8/5/2019

---

### Status Statement

Note: Fire Alarm System Installation

### Review Comments:

1. Please comply with GT yellow book requirements and provide smoke detectors throughout corridors and normally unoccupied spaces.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Alarm
-