
Plan Review Summary

Building Information

Project Name:	Boggs 3-11 Radiochemistry Lab	Floor/Room #:	3rd Floor Rooms 3-11
Building #:	103	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$500,000
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Cristina Fannin
Architect/Engineer of Record:	Leapley Construction/Jason Porter
Construction Manager:	Cristina Fannin
Aim Project Number:	0130-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	8/6/2019
Disposition:	Declined	Date Completed:	8/6/2019

Status Statement

Note: Add 3 smoke detectors and 2 strobes

Review Comments:

1. Please revise the Matrix Diagram to show duct detectors sending a supervisory signal, not a fire alarm signal.
2. Please provide battery calculations for the added strobes.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Permits Required:

1. Fire Alarm
-