
Plan Review Summary

Building Information

Project Name:	Boggs 3-13 Server Room Fit-Up	Floor/Room #:	3rd Floor Rooms 3-13
Building #:	103	Department:	Mechanical Engineering
Occupancy Type:	Business	Budget:	\$15,000.00
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Cristina Fannin
Architect/Engineer of Record:	Leapley Construction/Jason Porter
Construction Manager:	Cristina Fannin
Aim Project Number:	0453-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	8/6/2019
Disposition:	Declined	Date Completed:	8/6/2019

Status Statement

Note: Add 1 smoke detector and 1 strobe

Review Comments:

1. Please revise the Matrix Diagram to show a duct detector sending a supervisory signal, and not a fire alarm signal.
2. Please provide battery calculations for the added strobe.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Permits Required:

1. Fire Alarm
-