

151 Sixth Street, Suite 341 Atlanta, Georgia 30332 404-894-FIRE (3473)

Plan Review Summary

Building Information

Project Name: MARC/GTMI Sourabh Saha Lab

MARC/OTIVII Sourabii Sana La

Building #: 126
Occupancy Type: Bus

Business

Construction Type: IIB

Construction Manager:

Floor/Room #: Third Floor/320

Department: College of Engineering

Budget: \$200,000

Type of Review: Construction

Project Management

Project Manager:
Architect/Engineer of Record:

Bill Oswell d: Kyle Epste

Kyle Epstein Jennifer Disotell

Aim Project Number: 0534-2019

Reviewer Information

Reviewer Name: Jake LeJeune
Disposition: Declined

Date Received:

8/21/2019

Date Completed: 9/10/2019

Status Statement

Note: New lab in existing space

Review Comments:

- Please indicate that the laser curtain will be fire resistant and flame retardant in accordance with the 2012 editions of NFPA 101 and IFC.
- 2. Please acknowledge and indicate that the fire sprinklers will be quick response in accordance with the 2011 edition of NFPA 45, 6.2 and that a separate permit shall be obtained.
- 3. Please provide portable fire extinguishers in accordance with the 2011 edition of NFPA 45, 6.4.
- 4. Please classify this class D lab as a business occupancy in accordance with the 2011 edition of NFPA 45, 5.3.3.
- 5. Please provide the manufacturer specifications of the exhaust fans to show that section 8.7 of the 2011 edition of NFPA 45, is in compliance.
- 6. Please provide the chemical fume hood specifications to show that section 8.10 of the 2011 edition of NFPA 45, in in compliance.
- 7. Please indicate that inspections, testing, and maintenance of the chemical fume hood and exhaust systems will be in compliance with the 2011 edition of NFPA 45, 8.13.
- 8. Please provide the adjacent lab's Unit Hazard Classification to show that separation is not required, or required per the 2011 edition of NFPA 45, table 5.1.1.
- 9. Please provide the SDS sheets of all the gases to show compliance with the 2011 edition of NFPA 45, 11.1.4.3.
- 10. Sheet M-1: return airflow CFM- are we recirculating air to/from this lab? Not 100% exhaust? (EHS comment)
- 11. Please denote where granular Zinc will be stored and where work with it will safely take place.

General Note:

- 1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request
- 2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

- 1. Fire Emergency Response Plans
- 2. Red Book Completion and Fixed Location Designation

Plan / Shop Drawings Required:

- 1. Fire Suppression
- 2. Fire Alarm

Inspections Required:

- 1. Fire Safety Office Project Kick-Off Meeting
- 2. Thrust Block Inspections
- 3. Underground Pressure Test
- 4. System Flush
- 5. Sprinkler Pipe Inspections
- 6. Rough-in
- 7. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
- 8. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in. etc.)
- 9. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

- 1. Demolition
- 2. Construction / Interior Renovation
- 3. Fire Suppression System
- 4. Fire Alarm

