

Plan Review Summary

Building Information

Project Name:	Lukas Graber Lab Up-fit	Floor/Room #:	First Floor
Building #:	777	Department:	NEETRAC
Occupancy Type:	Business	Budget:	\$45,000.00
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Kynthia Gaines
Architect/Engineer of Record:	Stuart Thiel, Plexus R + D Architecture
Construction Manager:	Kynthia Gaines
Aim Project Number:	0219-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	9/11/2019
Disposition:	Declined	Date Completed:	9/12/2019

Comments:

EHS Comments:

1. Gases in SDS Sheets, but not listed on Hazmat inventory statement?
2. Safety shower, does it also have an eyewash station? I don't see one denoted there or at the sinks.
3. Privacy curtain consideration for safety shower?

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation