
Plan Review Summary

Building Information

Project Name:	Kendeda Building-AS BUILTS Fire Alarm	Floor/Room #:	
Building #:	210	Department:	Design and Construction
Occupancy Type:	Business	Budget:	\$18,600,000.00
Construction Type:	IIB	Type of Review:	Fire Alarm-AS-BUILTS

Project Management

Project Manager:	John DuConge
Architect/Engineer of Record:	Lord Aeck Sargent
Construction Manager:	Matt Williams
Aim Project Number:	0418-2017

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	9/13/2019
Disposition:	Declined	Date Completed:	9/13/2019

Status Statement

Note: Fire alarm as-built

Review Comments:

1. Declined – no central station reports supplied

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Plan / Shop Drawings Required:

1. Fire Suppression
 2. Fire Alarm
-
1. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)
-