

Plan Review Summary

Building Information

Project Name:	Coon Fire Alarm System Upgrades	Floor/Room #:	All Floors
Building #:	045	Department:	GT Fire and Life Safety Office
Occupancy Type:	Business	Budget:	\$500,000
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Cristina Fannin
Architect/Engineer of Record:	EMC Security/Gene Musco
Construction Manager:	Cristina Fannin
Aim Project Number:	0365-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	9/23/2019
Disposition:	Declined	Date Completed:	10/1/2019

Status Statement

Note: Fire Alarm System

Review Comments:

1. Please provide smoke detectors in the following locations in accordance with Georgia Tech Yellowbook standard.

Sheet FA2: Corridors; Fan room B91; Research Data Storage B48; Servers B77K
Sheet FA3: Mech. G93; G72; Closet G84; Storage G23B; AV G29B; INT G29A; AV G29C; INT G29D; Closet G21E
Sheet FA4: Data Storage 122; Closet 136A; JAN. 111; Data Storage 136; Storage 154
Sheet FA5: Closet 222; Closet 212; JAN. 211
Sheet FA6: Storage 402; JAN. 4
2. Please provide pull stations by all exit doors and provide a smoke and heat detector at the top of the elevator shaft and in the pit if applicable.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm