
Plan Review Summary

Building Information

Project Name:	Wood Dust Collection System-College of Engineering	Floor/Room #:	2nd Floor 2317
Building #:	135	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$250,000
Construction Type:	IVA	Type of Review:	Construction

Project Management

Project Manager:	Tony Gonzalez
Architect/Engineer of Record:	Schneider Wright, Inc.
Construction Manager:	Jennifer Disotell
Aim Project Number:	0452-2019

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	10/3/2019
Disposition:	Declined	Date Completed:	10/7/2019

Status Statement

Note: Adding a dust collector and new gate

Review Comments:

1. Gates are required to have a panic hardware to allow person to exit the area without having to use a key

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Permits Required:

1. Demolition
 2. Construction / Interior Renovation
 3. Fire Suppression System
 4. Fire Alarm
-