

---

## Plan Review Summary

---

### Building Information

---

Project Name:	Human Resources Hydraulic Passenger Elevator Renovation	Floor/Room #:	
Building #:	142	Department:	Facilities O & M
Occupancy Type:	Business	Budget:	\$250,000.00
Construction Type:	IIIA	Type of Review:	Construction

---

### Project Management

---

Project Manager:	Bill Oswell
Architect/Engineer of Record:	George Grant
Construction Manager:	Fenella Bryant
Aim Project Number:	0490-2019

---

### Reviewer Information

---

Reviewer Name:	Jerry Marrison	Date Received:	12/16/2019
Disposition:	Declined	Date Completed:	12/20/2019

---

### Status Statement

Note: Elevator refurb

### Review Comments:

1. Plan is declined
2. Page A-1; elevator room and hoistway must be 2 hour rated or sprinkled
3. Pan needs to be approved by State of Georgia

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
  2. Red Book Completion and Fixed Location Designation
-