
Plan Review Summary

Building Information

Project Name:	CRC Chiller Replacement	Floor/Room #:	Mechanical 1263
Building #:	160	Department:	CRC
Occupancy Type:	Business	Budget:	\$1,609,958.00
Construction Type:	IIIB	Type of Review:	Construction

Project Management

Project Manager:	Daniel Powell
Architect/Engineer of Record:	Jonathan Eveleth
Construction Manager:	
Aim Project Number:	0474-2019

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	12/19/2019
Disposition:	Declined	Date Completed:	12/30/2019

Status Statement

Note: CRC Chiller replacement

Review Comments:

1. No Code Summary
2. No Occupancy Classification
3. Drawing Scale

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Plan / Shop Drawings Required:

1. Fire Suppression
 2. Fire Alarm
-
1. System
 2. Fire Alarm
-