

---

## Plan Review Summary

---

### Building Information

Project Name:	Waterproofing & Drainage Improvements- Alumni House	Floor/Room #:	
Building #:	003	Department:	Alumni Association
Occupancy Type:	Business	Budget:	\$659,067
Construction Type:	IIB	Type of Review:	Construction

---

### Project Management

Project Manager:	Mark Wood
Architect/Engineer of Record:	Breedlove Land Planning
Construction Manager:	Mark Wood
Aim Project Number:	0342-2018

---

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	4/30/2019
Disposition:	Approved	Date Completed:	4/30/2019

---

### Status Statement

Note: Civil Site Work

### Review Comments:

1. Fire Department Access and Water Supply to the building shall remain unobstructed and in service throughout the duration of the project.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Construction / Interior Renovation 2019-SP-143
-