
Plan Review Summary

Building Information

Project Name:	Campus Services Warehouse CO Work	Floor/Room #:	Suites 100 & 200
Building #:	882	Department:	Housing
Occupancy Type:	Storage	Budget:	\$137,225.00
Construction Type:	IIIB	Type of Review:	Construction-REVISION

Project Management

Project Manager:	Daniel Powell
Architect/Engineer of Record:	Jeffrey Juliano
Construction Manager:	
Aim Project Number:	1814-7917

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	1/6/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	1/29/2020

Status Statement

Note: New stair addition and stairwell

Review Comments:

1. A-011 move fire extinguisher from current position to location marked on plan
2. A-011 all fire extinguishers will be marked using tent style identification markers
3. Provide stair details with tread and riser dimensions
4. A-502 Per NFPA 101 – 7.2.2.5.4.3 all tread nosing to be identified with a safety color.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation 2020-CP-010
-