
Plan Review Summary

Building Information

Project Name:	Brittain Dining Hall Re-roof	Floor/Room #:	
Building #:	012	Department:	GT Dining/GT Aux Services
Occupancy Type:	Other	Budget:	\$800,000.00
Construction Type:	IIIB	Type of Review:	Construction

Project Management

Project Manager:	Spencer Sheffield
Architect/Engineer of Record:	Make 3 Architecture/Planning/Design
Construction Manager:	Spencer Sheffield
Aim Project Number:	0306-2019

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	1/28/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	1/30/2020

Status Statement

Note: Reroof project

Review Comments:

1. Provide dumpster location
2. Follow hot works policy
3. No generators on roof

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. **Fire Safety Office Project Kick-Off Meeting**
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction 2020-CP-026
-