

---

## Plan Review Summary

---

### Building Information

Project Name:	Dalney Building-PV Installation	Floor/Room #:	Roof
Building #:	204	Department:	GTRC and PTS
Occupancy Type:	Business	Budget:	\$237,000
Construction Type:	IIIB	Type of Review:	Construction

---

### Project Management

Project Manager:	Brad Morris
Architect/Engineer of Record:	Methode Maniraguha
Construction Manager:	Fredrik Nilsson
Aim Project Number:	0370-2017

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	2/5/2020
Disposition:	Approved	Date Completed:	2/13/2020

---

### Status Statement

Note: PV Installation

### Review Comments:

1. Approved

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Construction / Interior Renovation                      2020-CP-031
-