

---

## Plan Review Summary

---

### Building Information

Project Name:	Ryan Sherman Lab Improvements-Structures	Floor/Room #:	Various Rooms
Building #:	149	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$200,000
Construction Type:	IIB	Type of Review:	Construction

---

### Project Management

Project Manager:	William T. Oswell
Architect/Engineer of Record:	William T. Oswell
Construction Manager:	Thomas Schneider
Aim Project Number:	0047-2020

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	2/6/2020
Disposition:	Approved	Date Completed:	2/18/2020

---

### Status Statement

Note: Refinishing lab

### Review Comments:

1. Approved

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Construction / Interior Renovation 2020-CP-032
-