

Plan Review Summary

Building Information

Project Name:	Griffin Track Press Box Demo	Floor/Room #:	
Building #:	080A	Department:	GT Athletic Association
Occupancy Type:	Business	Budget:	\$140,000.00
Construction Type:	VB	Type of Review:	Construction

Project Management

Project Manager:	Mitchell Shelton
Architect/Engineer of Record:	Marc Clear
Construction Manager:	Mitchell Shelton
Aim Project Number:	0219-2020

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	2/24/2020
Disposition:	Approved	Date Completed:	2/26/2020

Status Statement

Note: Bollards and fencing

Review Comments:

1. Approved for bollard and fencing placement

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction 2020-CP-045