
Plan Review Summary

Building Information

Project Name:	10th and Home Family Housing Wireless Upgrade	Floor/Room #:	All areas
Building #:	180	Department:	GT Housing
Occupancy Type:	Dormitory	Budget:	\$700,000.00
Construction Type:	IIIB	Type of Review:	Construction

Project Management

Project Manager:	Spencer Sheffield
Architect/Engineer of Record:	Bill Lawrence
Construction Manager:	Spencer Sheffield
Aim Project Number:	0036-2020

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	2/26/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	3/3/2020

Status Statement

Note: Wireless upgrade for housing

Review Comments:

1. All penetrations shall be sealed with UL listed GTFISO approved fire caulk

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Certificate of Completion (all work complete, close-out documents, etc.)

Permits Issued:

1. Construction: 2020-CP-047
-