
Plan Review Summary

Building Information

Project Name:	Bobby Dodd Stadium-Concert Layout	Floor/Room #:	
Building #:	017	Department:	GTAA
Occupancy Type:	Business	Budget:	
Construction Type:	IIB	Type of Review:	Construction-Concert Layout

Project Management

Project Manager:
Architect/Engineer of Record:
Construction Manager:
Aim Project Number:

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	2/27/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	2/28/2020

Status Statement

Note: Seating and stage layout only for this event. Crowd management staffing required, GTFSSO presence of 4 will be required. Max occupant load on life safety plan of 7,396.

Review Comments:

1. This approval is for the seating layout only
2. No vendor layout was provided and cannot be added
3. No description of any pyrotechnics
4. No changes to stage layout or seating layout permitted
5. Provide digital copy to GTFSSO office

Inspections Required:

1. Stage and seating set-up must be inspected prior to any event being started

Permits Required:

1. Pyrotechnics permit if it will be used
2. Flame effect permit if it will be used

Permits Issued:

1. Operational: 2020-CP-048
-