

## Plan Review Summary

### Building Information

Project Name:	Boggs AHU Refurbishment	Floor/Room #:	Roof
Building #:	103	Department:	Facilities
Occupancy Type:	Business	Budget:	\$900K
Construction Type:	IIB	Type of Review:	Construction

### Project Management

Project Manager:	Greg Spiro
Architect/Engineer of Record:	Tim North
Construction Manager:	Jennifer Disotell
Aim Project Number:	2019-0184

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/5/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	3/9/2020

### Review Comments:

1. Duct Smoke Detectors are required in units over 2000cfms per 2018 Mechanical Code.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Construction / Interior Renovation
2. Fire Alarm

### Permits Issued:

1. Construction / Interior Renovation: 2020-CP-058