
Plan Review Summary

Building Information

Project Name:	McGuire Lab Fit-Up	Floor/Room #:	2nd Floor, 2175
Building #:	147	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$150,000
Construction Type:	IA	Type of Review:	Construction

Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Warren Esptein-Kylie
Construction Manager:	Kynthia Gaines
Aim Project Number:	0137-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/11/2020
Disposition:	Approved	Date Completed:	4/29/2020

Status Statement

Note: Lab unit class D hazard NFPA 45; Lab is used for fossil processing and imaging; New equipment being installed and new floor plan/fixture plan; new partition being installed dividing the lab into 2 areas; minimal mechanical work for new space; Natural gas supply being capped off; new electrical work for new equipment

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2020-CP-063
-

