

Plan Review Summary

Building Information

Project Name:	Price Gilbert Crosland Library-Sideways Cafe	Floor/Room #:	Ground Floor/G110
Building #:	100/077	Department:	Auxiliary Services
Occupancy Type:	Business	Budget:	\$490,000.00
Construction Type:	IIB	Type of Review:	Construction-REVISION

Project Management

Project Manager:	Daniel Powell
Architect/Engineer of Record:	Brian Tanner
Construction Manager:	
Aim Project Number:	0368-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/13/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	3/20/2020

Review Comments:

1. KA101: If the Panini Grill will produce Grease Laden Vapors while cooking, then a Type I Hood with Fire suppression shall be permitted.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

Permits Issued: Construction / Interior Renovation:

2020-CP-074