

## Plan Review Summary

### Building Information

Project Name:	GLC-Analog to Room 236	Floor/Room #:	2
Building #:	170	Department:	Professional Education
Occupancy Type:	Business	Budget:	\$850,000.00
Construction Type:	IA	Type of Review:	Construction

### Project Management

Project Manager:	Maria del Mar Ceballos
Architect/Engineer of Record:	Sabrina Tate
Construction Manager:	Fenella Bryant
Aim Project Number:	0315-2018

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/19/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	3/31/2020

### Status Statement

Note: Renovation of room 236

### Review Comments:

1. This plan was reviewed as if this room has smoke protected assembly seating in accordance with the 2018 edition of NFPA 101, 13.4.2.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Demolition

2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

**Permits Issued:**

1. Construction / Interior Renovation:

2020-CP-076

---

