

---

## Plan Review Summary

---

### Building Information

Project Name:	Women's Basketball Locker Room-REVISION	Floor/Room #:	1st Floor, locker and lounge area
Building #:	73A	Department:	GT D+C
Occupancy Type:	Business	Budget:	\$650K
Construction Type:	IIB	Type of Review:	Construction-REVISION

---

### Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	Jim Winer
Construction Manager:	Brian Oliver-DPR
Aim Project Number:	2019-0312

---

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/25/2020
Disposition:	Approved	Date Completed:	3/26/2020

---

### Status Statement

Note: Women's Locker Room Renovation

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

### Permits Issued:

1. Construction / Interior Renovation: 2020-CP-078
-