

Plan Review Summary

Building Information

Project Name:	UA Whitaker-2nd Floor Wall Work	Floor/Room #:	Second Floor 2214 and 2215
Building #:	165	Department:	BME
Occupancy Type:	Business	Budget:	\$425,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	
Architect/Engineer of Record:	Amber Chellis-Omedo
Construction Manager:	Kynthia Gaines
Aim Project Number:	0492-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/25/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	4/1/2020

Status Statement

Note: Re-installation of wall/partition

Review Comments:

1. The type of gas will need to be known before certificate of completion is granted to verify proper protection if needed.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation

3. Fire Suppression System
4. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation:

2020-CP-086

