# Plan Review Summary

Building Information			
Project Name:	Savant 208B Renovation	Floor/Room #:	2nd/208B
Building #:	024	Department:	Office of International Education
Occupancy Type:	Business	Budget:	\$30,000
Construction Type:	IIB	Type of Review:	Construction
Project Management			
Project Manager:	Amber Chellis-Omedo	F 15 7	
Architect/Engineer of	Record: Amber Chellis-Omedo		
Construction Manage	er: Cristina Fannin		
Aim Project Number:	0251-2020		
Reviewer Information			
Reviewer Name:	Jake LeJeune	Date Received:	4/1/2020
Disposition:	Approved	Date Completed:	4/6/2020

#### General Note:

Georgia

Tech

- 1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request
- 2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot\_work

Environmental Health & Safety

## Additional Requirements (as needed):

- 1. Fire Emergency Response Plans
- 2. Red Book Completion and Fixed Location Designation

### Plan / Shop Drawings Required:

1. Fire Alarm

### Inspections Required:

- 1. Fire Safety Office Project Kick-Off Meeting
- 2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
- 3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
- 4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

- 1. Demolition
- 2. Construction / Interior Renovation
- 3. Fire Alarm

### Permits Issued:

1. Construction / Interior Renovation:

2020-CP-088

