
Plan Review Summary

Building Information

Project Name:	Bobby Dodd Restrooms Renovation	Floor/Room #:	All Concourse restrooms
Building #:	017	Department:	GT Athletic Association
Occupancy Type:	Business	Budget:	\$1,000,000.00
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Mark Wood
Architect/Engineer of Record:	Tony Menefee
Construction Manager:	Mark Wood
Aim Project Number:	0161-2020

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	5/6/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	5/15/2020

Status Statement

Note: Renovations of restrooms at Bobby Dodd

Review Comments:

1. Please ensure all restrooms have emergency lighting that has battery back-up

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation

Permits Issued:

1. Construction / Interior Renovation: 2020-CP-117
-