

Plan Review Summary

Building Information

Project Name:	CEE Office Renovations-Ford ES&T	Floor/Room #:	Floor 3, Rooms 3214,3216,3221,3223,3225
Building #:	147	Department:	CEE
Occupancy Type:	Business	Budget:	\$150,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	William Oswell
Architect/Engineer of Record:	William Oswell
Construction Manager:	Cristina Fannin
Aim Project Number:	0344-2019

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	5/22/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	6/2/2020

Status Statement

Note: Room renovations of 3 offices and 1 breakroom of cabinets and minor coverings

Review Comments:

1. Per page A103; D7 & D8 fire strobe relocations please submit fire alarm drawings

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2020-CP-135