

Plan Review Summary

Building Information

Project Name:	Ford ES&T Ocean Visualization Room	Floor/Room #:	Floor 3, Rooms 3243, 3235
Building #:	147	Department:	COS
Occupancy Type:	Business	Budget:	\$100,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	William T Oswell
Architect/Engineer of Record:	William T Oswell
Construction Manager:	Cristina Fannin
Aim Project Number:	0259-2019

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	5/22/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	6/2/2020

Status Statement

Note: Renovations of 2 offices, removal of partition wall to create one larger meeting/breakroom

Review Comments:

1. Per A101, #10 Fire extinguisher location will need to be moved. Furniture plans show it being blocked. Extinguisher shall be marked with a tent sign approved by GTF SO
2. Fire suppression drawings will need to be submitted as well due to partition wall being removed

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System

Permits Issued:

1. Construction / Interior Renovation: 2020-CP-136