
Plan Review Summary

Building Information

Project Name:	Lyman Hall Suite 206 Real Estate Renovation	Floor/Room #:	206
Building #:	029C	Department:	Design & Construction
Occupancy Type:	Business	Budget:	\$105,000
Construction Type:	IIIB	Type of Review:	Construction

Project Management

Project Manager:	Allison Gerstung
Architect/Engineer of Record:	Bill Oswell
Construction Manager:	Cristina Fannin
Aim Project Number:	0242-2020

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	5/22/2020
Disposition:	Approved	Date Completed:	5/26/2020

Status Statement

Note: Remove door and closer

Review Comments:

1. Approved

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation: 2020-CP-138
-