

---

## Plan Review Summary

---

### Building Information

Project Name:	Harper Wind Tunnel Renovation Phase 1	Floor/Room #:	Floor 1; Rooms 144, 145, 146
Building #:	40	Department:	COE
Occupancy Type:	Business	Budget:	\$100,000
Construction Type:	IIB	Type of Review:	Construction

---

### Project Management

Project Manager:	William T. Oswell
Architect/Engineer of Record:	William T. Oswell
Construction Manager:	Mitchell Shelton
Aim Project Number:	0259-2020

---

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	6/2/2020
Disposition:	Approved	Date Completed:	6/10/2020

---

### Status Statement

Note: Repair damaged drywall; divert water from the mechanical room to the existing drains; install new LED lighting in the office areas; grind and polish existing concrete floors; and repaint the walls and ceilings

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Construction / Interior Renovation: 2020-CP-148
-