
Plan Review Summary

Building Information

Project Name:	Smith Residence Hall FFE Refreshment	Floor/Room #:	
Building #:	006	Department:	GT Housing
Occupancy Type:	Dormitory	Budget:	\$7500,000.00
Construction Type:	IIIA	Type of Review:	Construction

Project Management

Project Manager:	Polly Patton
Architect/Engineer of Record:	SWI
Construction Manager:	Polly Patton
Aim Project Number:	0440-2020

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/3/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	6/8/2020

Status Statement

Note: Interior renovations

Review Comments:

1. Multiple pages: Per NFPA 10: 6.1.3.10.2 – Cabinets shall be marked with tents relayed to project designer

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Interior Renovation: 2020-CP-151
-