

Plan Review Summary

Building Information

Project Name:	Russ Chandler Baseball Renovation	Floor/Room #:	
Building #:	168	Department:	Design and Construction
Occupancy Type:	Assembly	Budget:	\$10M
Construction Type:	IIIB	Type of Review:	Construction-REVISION

Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	Cheng-Li Wang
Construction Manager:	Jackie Avello
Aim Project Number:	2020-0359

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/30/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	7/7/2020

Status Statement

Note: Demolition of part of existing baseball stadium; new construction of baseball stadium building; MEP, fire alarm system and fire sprinkler systems

Review Comments:

1. No parking signs shall be placed designating fire lanes and shall also be painted on the ground.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Thrust Block Inspections
3. Underground Pressure Test
4. System Flush
5. Sprinkler Pipe Inspections
6. Rough-in
7. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
8. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
9. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System
2. Fire Alarm

Permits Issued:

1. Construction: 2020-CP-188
-

