
Plan Review Summary

Building Information

Project Name:	Bunger Henry-Microgrid Test Bed Installation-REVISION	Floor/Room #:	2nd Floor/RM240
Building #:	086	Department:	ECE
Occupancy Type:	Business	Budget:	\$63,517.00
Construction Type:	IIB	Type of Review:	Construction-REVISION

Project Management

Project Manager:	Sam DahDah
Architect/Engineer of Record:	Allen J. Thompson
Construction Manager:	Blake Baklini
Aim Project Number:	0186-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/6/2020
Disposition:	Approved	Date Completed:	7/16/2020

Status Statement

Note: New Generator; Pad; Gas piping; Microgrid Test Bed

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation: 2020-CP-200
-