

Plan Review Summary

Building Information

Project Name:	CODA Backfill-EXCEL Relocation Phase 1-REVISION	Floor/Room #:	Ground, 1st, 2nd, 3rd floors
Building #:	155, 155B	Department:	CPSM
Occupancy Type:	Business	Budget:	\$999,999
Construction Type:	Choose an item.	Type of Review:	Construction-REVISION

Project Management

Project Manager:	Carla Barbour
Architect/Engineer of Record:	ASD/SKY
Construction Manager:	Carla Barbour
Aim Project Number:	0334-200, 0100-2020

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	7/7/2020
Disposition:	Approved	Date Completed:	7/13/2020

Status Statement

Note: MEP work; New lighting and audio/visual devices

Review Comments:

1. Approved

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System
2. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2020-CP-201