
Plan Review Summary

Building Information

Project Name:	Crosland Tower-Price Gilbert Day 2 Projects	Floor/Room #:	Connector Bridge
Building #:	77	Department:	GT Design and Construction
Occupancy Type:	Business	Budget:	\$20,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	Stuart Romm
Construction Manager:	
Aim Project Number:	0411-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/15/2020
Disposition:	Approved	Date Completed:	7/28/2020

Status Statement

Note: Bench installations on connector bridge

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation: 2020-CP-210
-