

---

## Plan Review Summary

---

### Building Information

---

Project Name:	1747 CCRF B12 ELSYS Open Lab Renovation-REVISION	Floor/Room #:	1ST
Building #:	763	Department:	SSD
Occupancy Type:	Business	Budget:	\$430,000
Construction Type:	IIB	Type of Review:	Construction

---

### Project Management

---

Project Manager:	Nic Palfrey
Architect/Engineer of Record:	Dennis Carter
Construction Manager:	Richard Whitehead
Aim Project Number:	0212-2020

---

### Reviewer Information

---

Reviewer Name:	Jake LeJeune	Date Received:	7/15/2020
Disposition:	Approved	Date Completed:	7/28/2020

---

### Status Statement

Note: Lab Renovations; No gases, no chemicals

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Suppression System
2. Fire Alarm

### Permits Issued:

1. Construction / Interior Renovation: 2020-CP-211
-