
Plan Review Summary

Building Information

Project Name:	Alumni House HVAC Upgrades-Phase 3	Floor/Room #:	3rd Floor
Building #:	003	Department:	GT Alumni Association
Occupancy Type:	Business	Budget:	\$395,389.00
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Mark Wood
Architect/Engineer of Record:	Jon Jimenez
Construction Manager:	Mark Wood
Aim Project Number:	0074-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/22/2020
Disposition:	Approved	Date Completed:	7/28/2020

Status Statement

Note: HVAC upgrades 3rd floor

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation: 2020-CP-216
-