

---

## Plan Review Summary

---

### Building Information

Project Name:	Ford ES&T Naif Lab Fit-Up-REVISION	Floor/Room #:	First Floor/1235
Building #:	147	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$150,000
Construction Type:	IIIB	Type of Review:	Construction-REVISION

---

### Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	D&C, Ngugi Mathu
Construction Manager:	Blake Baklini
Aim Project Number:	0396-2020

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	7/22/2020
Disposition:	Approved	Date Completed:	7/23/2020

---

### Status Statement

Note: "Lab" upfit

### Review Comments:

1. Approved

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Suppression System
2. Fire Alarm

### Permits Issued:

1. Construction / Interior Renovation: 2020-CP-219
-