
Plan Review Summary

Building Information

Project Name:	Perry-Matheson Partial Interior Renovation	Floor/Room #:	All
Building #:	91, 92	Department:	Housing and Residence Life
Occupancy Type:	Dormitory	Budget:	
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Brad Morris
Architect/Engineer of Record:	Becky Williams, HLG Studio
Construction Manager:	
Aim Project Number:	0460-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	9/29/2020
Disposition:	Approved	Date Completed:	10/14/2020

Status Statement

Note: Electrical Lighting and Finishes Renovation and Demolition

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System
2. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2020-CP-263
-