
Plan Review Summary

Building Information

Project Name:	Tin Drum Refresh	Floor/Room #:	1st Floor
Building #:	170	Department:	Auxiliary Operations
Occupancy Type:	Business	Budget:	\$250,000.00
Construction Type:	IIIB	Type of Review:	Construction

Project Management

Project Manager:	Daniel Powell
Architect/Engineer of Record:	Louis Yuan
Construction Manager:	Paul Yum
Aim Project Number:	PRF Submitted

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	10/6/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	10/14/2020

Status Statement

Note: Tile replacement and creating new slope for drainage

Review Comments:

1. Posi Locks shall be required for all commercial cooking appliance
2. Supply kitchen equipment placement diagrams for file
3. Open violation shall be corrected

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation: 2020-CP-277
-