

---

## Plan Review Summary

---

### Building Information

Project Name:	Lang Lab Fit-Up-Ford ES&T	Floor/Room #:	3rd floor: 3131 & 3139
Building #:	147	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$209,000
Construction Type:	IIB	Type of Review:	Construction

---

### Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Warren Epstein Architects
Construction Manager:	Cristina Fannin
Aim Project Number:	0406-2020

---

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	10/8/2020
Disposition:	Approved	Date Completed:	10/14/2020

---

### Status Statement

Note: New Lab Renovation; equipment, plumbing, electrical, mechanical, fire sprinklers, fire alarm system

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

### Permits Issued:

1. Construction / Interior Renovation: 2020-CP-278
-