
Plan Review Summary

Building Information

Project Name:	Baker-Rm 350 Modifications-GTRI 1800	Floor/Room #:	3rd Floor, RM 350
Building #:	099	Department:	GTRI
Occupancy Type:	Business	Budget:	\$50,000.00
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Michelle Doyle
Architect/Engineer of Record:	Dennis G. Carter, PE
Construction Manager:	Anne Russell
Aim Project Number:	0018-2021

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	10/13/2020
Disposition:	Approved	Date Completed:	10/16/2020

Status Statement

Note: New Partition/wall installation; electrical and mechanical work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System
2. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2020-CP-282
-