
Plan Review Summary

Building Information

Project Name:	GT Police Department Basement Modification	Floor/Room #:	Basement
Building #:	211	Department:	Police Department
Occupancy Type:	Business	Budget:	\$20,000.00
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Thomas Schneider
Architect/Engineer of Record:	Bill Oswell
Construction Manager:	
Aim Project Number:	0053-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	10/13/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	10/16/2020

Status Statement

Note: New partition and double doors; new exit sign added

Review Comments:

1. Fire Sprinkler spacing and head placement shall not be more than half the spacing requirement distance to the wall per NFPA 13.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation: 2020-CP-286
-