

Plan Review Summary

Building Information

Project Name:	Pettit-Equipment Install Cleanroom	Floor/Room #:	Cleanroom Floor 021 & 028
Building #:	095	Department:	IEN
Occupancy Type:	Business	Budget:	\$70,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Jennifer Disotell
Architect/Engineer of Record:	Ngugi Mathu, Sam Dahdah
Construction Manager:	Jennifer Disotell
Aim Project Number:	0042-2021

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	11/3/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	11/18/2020

Status Statement

Note: Cleanroom labs for coating techniques for aluminum sheet; new equipment, relocated equipment

Review Comments:

1. Please provide manufacturer specifications of all equipment including the existing fume hoods.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

Permits Issued:

