
Plan Review Summary

Building Information

Project Name:	Nanotech Chiller Replacement	Floor/Room #:	Chiller Room, Ground Floor
Building #:	181	Department:	Facilities
Occupancy Type:	Business	Budget:	\$1,525,091
Construction Type:	IIIB	Type of Review:	Construction

Project Management

Project Manager:	Mark Wood
Architect/Engineer of Record:	Sam Dahdah
Construction Manager:	Mark Wood
Aim Project Number:	0144-2019

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	11/9/2020
Disposition:	Approved	Date Completed:	11/16/2020

Status Statement

Note: Chiller replacement

Review Comments:

1. Please make sure to notify GTFISO of any power outages

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction: 2020-CP-295
-